



Slocum Water Supply Corporation 2019 Consumer Confidence Report



Annual Water Quality Report for the period of January 1 to December 31, 2019

For more information regarding this report contact the business office at 903-478-3486

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al teléfono: (903) 478-3486

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The Presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring, or be the result of oil and gas production and mining activities.

In order to insure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer, persons who have undergone organ transplants, those who are undergoing treatment with steroids, and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and in plumbing components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Slocum Water Supply Corporation operates under a (7) seven person Board of Directors. Regular monthly meetings are held every 2nd Thursday of each month at 6:00 pm at 5720 East State Highway 294, Elkhart, Texas 75839 (Across from the Slocum I.S.D.)

We on a daily basis strive to improve the growth of our system and the quality of our water. If you should have any questions regarding this report, you may call the office during the hours of 8 am to 3 pm at (903)478-3486, or email us at slocumwscorp@gmail.com. We also have a website you can visit at: www.slocumwsc.myrralwater.com.



**Operator : Brian Chapin
Office Manager: Lori Martin**

Information about Source Water

TCDE completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact Slocum Water Supply Corporation Board of Directors at (903) 478-3486.

Definitions and Abbreviations

Definitions and Abbreviations:

The following tables contain scientific terms and measures, some of which may require explanation. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLs allow for a margin of safety.

Regulatory compliance with some MCLs are based on running annual average of monthly samples. A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLs as possible using the best available treatment technology.

MCLs allow for a margin of safety. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

million fibers per liter (a measure of asbestos)

millirems per year (a measure of radiation absorbed by the body)

not applicable.

nephelometric turbidity units (a measure of turbidity)

picouries per liter (a measure of radioactivity)

micrograms per liter or parts per billion-or one ounce in 7,350,000 gallons of water.

milligrams per liter or parts per million-or one ounce in 7,350 gallons of water.

parts per quadrillion, or picograms per liter (pg/L)

parts per trillion, or nanograms per liter (ng/L)

A required process intended to reduce the level of a contaminant in drinking water.

Treatment Technique or TT:

Lead and Copper	Date Sampled	MCL G	Action Level (AL)	90th Percentile AL	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/07/2017	1.3	1.3	0.218	0	ppm	N	Erosion of natural deposits. Leaching from wood preservatives. Corrosion of household plumbing systems.
Lead	09/07/2017	0	15	3.89	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

SLOCUM WSC provides ground water from CARRIZO/WILCOX AQUIFER

Located in Anderson County

PWS# TX0010028

2019 Water Quality Test Results

Disinfection By-Products (THAAS)	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Unit	Violation	Likely Source of Contamination
Halacetic Acids	2019	8	7.2-7.9	No goal for the total	60	ppb	N	By-product of drinking water disinfection
Total Trihalomethanes (TTHM)	2019	52	20.1-52.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCL G	MCL	Unit	Violation	Likely Source of Contamination
Barium	2019	0.0052	0.0052-0.0052	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2019	1.4	1.4-1.4	4	4.0	ppm	N	Erosion of natural deposits; Beer additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (measured as Nitrogen)	2019	0.106	0.0319-0.106	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Unit	Violation	Likely Source of Contamination
Combined Radium 226/228	04/02/2015	1.5	1.5-1.5	0	5	pCi/L	N	Erosion of natural deposits

Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDL G	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chlorine	2019	1.17	0.5-2.0	4	4	ppm	N	Water additive used to control microbes.